

Adjusting the Slow Close Timing

1. The slow close cartridge is factory preset at 10 seconds @ 60 PSI. Depending on the inlet water pressure and water temperature this timing can vary. If timing need to be changed, remove the handle(A) by loosening allen screw (B).
2. With the help of flat head screwdriver, loosen the screw to decrease the timing and tighten the screw to increase the timing. The timing can be adjusted from 0 to 60 seconds depending on the inlet pressure and water temperature.
3. Once the satisfactory timing has been adjusted, install the handle (A) by tightening allen screw (B).

